



T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690 Model No.

EC-3102-SMT8V05

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com			
	ITEM NO.	SALES NO.	DESCRIPTION
	1	B-0199-08-N05	VR 0.5 GPM Spray Device, 13/16-27 UN Male w/ Key
	2	017195-45	Angled Sensor w/ Cable
	3	018251-45	ChekPoint 8" C-C SMT Deck Plate
	4	018541-45	M4 x 20mm, SS, Torx VR FH Screw
	5	018249-45	Handle
	6	018248-45	Temperature Limit Stop
	7	EC-SMT	Above Deck Thermostatic Mixing Valve w/ Handle
17	8	016297-45	Inlet Hose, Faucet, 1/2" NPSM-F x 1/4" NPSM-F
2	9	016647-45	ChekPoint Module (Grey)
	10	EC-FILTER	Replacement Filter
	11	002534-25	Close Nipple, 1/2" NPT
9	12	5EF-0002	Plug-in AC Transformer
	13	016167-45	Supply Hose, 1/2" NPSM Female x 1/2" NPSM Female
3 5	14	5EF-0005	Supply Hose, 9/16-24 Female x 1/2" NPSM
			A Maximum of (8) ChekPoint Faucets can be Hardwire Connected and Powered by EC-HARDWIRE ChekPoint Hardwire AC Transformer. (Sold Separately)
14			 Label for Flow Control Switch Settings is Located on Inside of Back Cover. Flow Control Switches are Located Inside Module Housing in Black Box Next to Battery Compartment. *Switches are Set to DEFAULT Position: - Auto Time Out = 15 Seconds
		3)	- Shut Off Delay = 1 Second - Auto Flush = OFF
018543-45 015425-45 VR Screw L-Key VR Aerator Key	<u>(</u>	9	Remove (4) Screws and Back Cover to
*Available Water Flow Control Selections: - Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min - Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec - Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF			
Product Specifications:			Product Compliance:
Chrome Plated Brass Electronic Faucet: S w/ 8" Centers Deck Plate, Above Deck Sid Mixing Valve w/ Check Valves, 0.5 GPM V Module with Internal Flow Control Setting	de Mo /R Sp	unt adjustable The ray Device, AC/D	C Control NSF 372 (Low Lead Content)
			ASSE 1070 (TMV)
Drawn: AMG Checked: JRM	Approv	ed: JHB Dat	e: 09/10/18 Scale: NTS Sheet: 2 of 2