Tes

T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690 Model No.

EC-3107-HG

Item No.

ASME A112.18.1 / CSA B125.1

NSF 61 - Section 9 NSF 372 (Low Lead Content)

ANSI A117.1 (ADA)

UL 1951

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

Travelers rest, 66. 666-476-4165 Girli Valley, 674	1000- 1 20-0100 1 ax. 0	04-004-0010 WWW.tsbia33.co	
	Te-	This Space for Architect/Er	ngineer Approval
ı 6 1/8" ı	(5.)	Job Name	Date
[156mm]	ADA Compliant	Model Specified	Quantity
	TS.	Customer/Wholesaler	
	ChekPoint [™]	Contractor	
		Architect/Engineer	
2.2 GP Vandal 1/2" NPSM x 1/4" NPSM 18" [457mm] Flexible Stainless Steel Hose Hydro-Generator Power Supply, No AA Batteries or AC Adapter Needed to Supply Power to Faucet Temperature Mixing Valve w/ Integral Check Valves	[92mm x Water R w/ Intern AC or Do if Hydro- Hardwire	1 3/4" [44mm] Maximum Thickness Optional 100-240 VAC Ada 71" [1800mm] Long Power (Remove Rubber Plugs on Module and Cable to Conn 4 3/16" x 2" Deep x 106mm x 51mm] esistant Control Module Bo al Flow Control Setting Sw C Operated w/ (4) AA Batte C Operated w/ (4) AA Batte C Capable Using Terminals ession x 1/2" NPSM lexible Stainless	c Cable (Included). nect) ox (Grey) ottches, ories
Rough-In Requirement: (2) 1" [25mm] Mounting Holes on 4" [102mm]	Centers		
Product Specifications:		Product Compliar	ice:

Drawn: DMH Checked: MRC Approved: JHB Date: 05/14/20 Scale: 1:6 Sheet: 1 of 2

Chrome Plated Brass Electronic Faucet: 4" c/c Deck Mount, Rigid Gooseneck,

2.2 GPM VR Aerator, AC/DC Control Module w/ Internal Flow Control Setting

Switches, Temperature Control Mixing Valve w/ Integral Check Valves, Hydro-Generator & 18" Hot & Cold Supply Stop Flexible Connector Hoses



(5)

T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690


Model No.

EC-3107-HG

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

ITEM NO.	SALES NO.	DESCRIPTION
1	006575-45	-015 O-Ring
2	044A	3/8" to Aerator Adapter
3	B-0199-06	Aerator, Vandal Resistant
4	015425-45	Vandal Resistant Key
5	017195-45	Angled Sensor w/ Cable
6	016297-45	Inlet Hose, Faucet, 1/2" NPSM-F x 1/4" NPSM-F
7	016647-45	ChekPoint Module (Grey)
8	5EF-0002	Plug-in AC Transformer
9	5EF-0006	Mechanical Mixing Valve
10	5EF-0005	Supply Hose, 9/16-24 Female x 1/2" NPSM
11	017506-45	1/2" NPSM Swivel Coupling
12	EC-HYDROGEN	HydroGenerator Power Supply
13	EC-FILTER	Replacement Filter



Label for Flow Control Switch Settings is Located on Inside of Back Cover.

Flow Control Switches are Located Inside Module Housing in Black Box Next to Battery Compartment.

- *Switches are Set to DEFAULT Position:
 - Auto Time Out = 15 Seconds
 - Shut Off Delay = 1 Second
 - Auto Flush = OFF

Remove (4) Screws and Back Cover to Access Switches.

- *Available Water Flow Control Selections:

(6)

- Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min
 Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec
 Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF

Product Specifications:

Chrome Plated Brass Electronic Faucet: 4" c/c Deck Mount, Rigid Gooseneck, 2.2 GPM VR Aerator, AC/DC Control Module w/ Internal Flow Control Setting Switches, Temperature Control Mixing Valve w/ Integral Check Valves, Hydro-Generator & 18" Hot & Cold Supply Stop Flexible Connector Hoses

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) UL 1951

Drawn: DMH Checked: MRC Approved: JHB Date: 05/14/20 Scale: NTS Sheet: 2 o	Drawn: DMH	Checked: MF	RC Approved:	JHB	Date: 0	5/14/20	Scale:	NTS	Sheet: 2 of
---	------------	-------------	--------------	-----	---------	---------	--------	-----	-------------